

MILLER ENGINEERS & ASSOCIATES, INC.
CONSULTING ENGINEERS & LAND SURVEYORS

GLENN E. MILLER, P.E. & P.L.S.
JOHN C. FORE, JR., P.E.
LAMON G. MILLER, P.L.S.
REID A. MILLER, P.E.
JOEL J. MILLER, P.E.
JULES DARDIN, E.I.



November 18, 2003

601 MAIN STREET
P. O. BOX 223
FRANKLIN, LOUISIANA 70538
OFFICE: (337) 828-1950 - Franklin
(985) 385-6611 - Morgan City
FAX: (337) 828-5388
E-MAIL: millengr@cox-internet.com

Mr. Dale Touchette
Louisiana Department of Transportation & Development
P.O. Box 3648
Lafayette, LA 70502

**Re: Water Distribution Line & Sewer Force Main To Serve Proposed
Civic Center For The St. Mary Parish Recreation District No. 5
M. E. & A. Project No. 10689-1**

Dear Mr. Touchette:

The St. Mary Parish Recreation District No. 5 proposes to construct an 8" water main and a 3" sewer force main for a proposed civic center. The water main parallels LA Hwy. 318 and crosses U.S. Hwy. 90. The sewer force main also parallels LA Hwy. 318, then turns and parallels U.S. Hwy. 90.

Enclosed please find four (4) copies of each Project Permit with attachments and drawings for proposed work within the right-of-ways of LA Hwy. 318 and U.S. Hwy. 90.

We are hereby requesting the Department's approval and/or comments at your earliest possible convenience.

Should you have any questions, please contact our office.

Sincerely,


MILLER ENGINEERS & ASSOCIATES, INC.

Jules M. Darden

Jules M. Darden, E.I.

jmd/

Encl.



VICINITY MAP


Scale: 1000' 500' 1000'

Copied From U.S.C. & G. S. Quadrangle
Franklin, Kemper, Jeanerette & Charenton, Louisiana 1990



Proposed: 8" C-900 P.V.C. Water Main
Crossing: U.S. Hwy. 90
Situated In: Sec. 71, T13S-R8E
St. Mary Parish, Louisiana
Application By: St. Mary Parish
Recreation District No. 5
Date: November, 2003

Sheet 1 of 2


03017067



Plan



Profile



Proposed: 8" C-900 P.V.C. Water Main
Crossing: U.S. Hwy. 90
Situated In: Sec. 71, T13S-R8E
St. Mary Parish, Louisiana
Application By: St. Mary Parish
Recreation District No. 5
Date: November, 2003
Sheet 2 of 2

03017067

**PIPE DATA SHEET
FOR PROPOSED INSTALLATIONS**

HIGHWAY NO. : U.S. Hwy. 90

CONTROL SECTION: 424-05

OWNER OF PROPOSED FACILITY: St. Mary Parish Recreation District No. 5

DATA	CARRIER PIPE	CASING (if used)
Contents to be handled	Potable Water	—
Pipe Material	P.V.C.	Steel
Specification & Grade of Pipe	C-900 DR 18	Grade A
Outside Diameter (inches)	9.050	16
Wall Thickness	0.503	0.25
Yield Strength (PSI)	N/A	30,000
Maximum allowable operating pressure (PSIG)	125	N/A
Class Location (for gas line)	N/A	N/A
Type of Joint (welded, mechanical, joint, etc.)	Mechanical	Welded
Method of installation (bore, open cut)	Bore	Bore
Location (crossing or parallel)	Crossing	Crossing
Min. Depth beneath roadway surface	5'	5'
Min. Depth beneath ditches or drainage structures	2'	2'
Coating Material	N/A	N/A
Cathodic Material	N/A	N/A

This proposed installation is in compliance with Department Standards

Dale Touchette
DISTRICT PERMIT SPECIALIST