

Three (3) copies of the application and drawing are required for Project Permit.

Serial No. 03017070

DOTD 03-41-0593
REV. 11/87

Four (4) copies of the application and drawing are required for Interstate Project Permit.

Entered in Computer File _____
Initial and Date _____

STATE OF LOUISIANA
DEPARTMENT OF TRANSPORTATION AND DEVELOPMENT
PROJECT PERMIT
(Required by State Law)

DISTRICT APPROVAL

By Dale Touchette Date 11-21-03

Control 424 Unit 05

St. Mary Parish Recreation District No. 5, hereinafter termed
Name of Applicant

the applicant, requests a permit for the use and occupancy of the right-of-way of State Highway

No. U.S. Hwy. 90 in St. Mary Parish, located as follows:

Beginning approx. 133' from the intersection of U.S. Hwy. 90 Frontage Road and La. Hwy. 318 going southeast along U.S. Hwy. 90 Frontage Road for approx. 2,250' as shown on the Plans.

for the installation, operation and maintenance of the following described project: PARALLEL - 2,250' 3" PE 3408 H.D.P.E. sewer force main (SDR 11) inside U.S. Hwy. 90 Frontage Road right-of-way as shown on the Plans

SIGNED: R. Craig A. Math DATE: 11/17/03
Owner

DO NOT WRITE IN THIS SPACE
(For use by Federal Highway Administration for permits on Interstate only)


St. Mary Parish Recreation District No. 5
Owner's Name (Typed or Printed)
P. O. Box 579
Street or P.O. Box
Franklin LA. 70538
City or Town State Zip Code
337-828-5703
Telephone No.

NOTES: This permit shall be available at the site where and when work is being done.
Applicant must notify District Permit Specialist, Phone Number: DALE TOUCHETTE (337) 262-6127
prior to beginning work and after work is completed.

DATE ISSUED: 11/21/03
EXPIRATION DATE: 05/21/04

BY: [Signature]
DOTD MAINTENANCE ENGINEERING ADMINISTRATOR

The following general conditions and standards shall apply: ASSISTANT MAINTENANCE ENGINEER



VICINITY MAP

Scale: 1000' 500' 0' 1000'

Copied From U.S.C. & G. S. Quadrangle
Franklin, Kemper, Jeanerette & Charenton, Louisiana 1980

03017010

Proposed: 3" H.D.P.E. Force Main
Along: U.S. Hwy. 90 Frontage Road
Situated In: Sec. 69 & 71, T13S-R8E
St. Mary Parish, Louisiana
Application By: St. Mary Parish
Recreation District No. 5
Date: November, 2003

Sheet 1 of 1

**PIPE DATA SHEET
FOR PROPOSED INSTALLATIONS**

HIGHWAY NO. : U.S. Hwy. 90

CONTROL SECTION: 424-05

OWNER OF PROPOSED FACILITY: St. Mary Parish Recreation District No. 5

DATA	CARRIER PIPE	CASING (if used)
Contents to be handled	Sanitary Sewer	
Pipe Material	H.D.P.E.	
Specification & Grade of Pipe	PE 3408 (SDR 11)	
Outside Diameter (inches)	3.96	
Wall Thickness	0.37	
Yield Strength (PSI)	N/A	
Maximum allowable operating pressure (PSIG)	15	
Class Location (for gas line)	N/A	
Type of Joint (welded, mechanical, joint, etc.)	Fusion Welded	
Method of installation (bore, open cut)	Open Cut	
Location (crossing or parallel)	Parallel	
Min. Depth beneath roadway surface	5'	
Min. Depth beneath ditches or drainage structures	2'	
Coating Material	N/A	
Cathodic Material	N/A	

This proposed installation is in compliance with Department Standards

Dale Touchette
DISTRICT PERMIT SPECIALIST